


Supply air			THOR TB2			Exhaust air			THOR TB2			Weight 1587 kg			project number 317-077			Additional project name			Pos no 2000		
Airflow	m³/h	21570	Airflow	m³/h	21320	Quantity		scale		Project KLINIK A CIECHANOW													
Ext. pressure	Pa	900	Ext. pressure	Pa	500	1		1:50															
Tot. pressure	Pa	11598	Tot. pressure	Pa	875			Name		Date		LV-Position N2W2											
Motor power	kW	2,200	Motor power	kW	1,100	User		S. Milewski		17-03-14		BE: 115-2020-G						File type		Order			
PHW-heating I	kW	24,18				airCalc++		Version		3.20.180		AB NR:											
PCW-cooling	kW	16,09				Program		Version		3.20.180 / 54.1		Panel thickness				50,0 mm				Drawing ID			
						Printed				20-08-10		internal number								Voltage		3x400 V / 50 Hz	
												Type  Model											
												KU 4-M-DV50S-H											