


Supply air			THOR TB2			Exhaust air			THOR TB2			Weight 1080 kg			project number 317-077			Additional project name			Pos no 3		
Airflow	m³/h	1290	Airflow	m³/h	790	Quantity	scale 1:50		Project KLINIK A CIECHANOW														
Ext. pressure	Pa	300	Ext. pressure	Pa	300			Name	Date	LV-Position N2W2													
Tot. pressure	Pa	809	Tot. pressure	Pa	623	User	S. Milewski		17-03-14		BE: 115-2020-G						File type Order						
Motor power	kW	1,900	Motor power	kW	1,800	airCalc++ Version		3.20.180		AB NR:													
PHW-heating I	kW	10,40				Program Version		3.20.180 / 54.1		Panel thickness 50,0 mm						Drawing ID							
						Printed		20-09-14		internal number						Voltage 3x400 V / 50 Hz							
									Type Model														