



The device dimensions specified in the offer phase can change in the case of an order.

Supply air		THOR TB2	Weight		198 kg	project number		317-077	Additional project name		Pos no	
Airflow	m³/h	1710	Quantity		1	scale		1:25	Project			KLINIKA CIECHANOW
Ext. pressure	Pa	200	Name		Date		LV-Position					
Tot. pressure	Pa	300	User	S. Milewski		17-03-14		BE:		115-2020-G	File type	Order
Motor power	kW	1,800	Aircalc++		Version		3.20.180		AB NR:			
E-heating	kW	26,06 / 3x400 V	Program		Version		3.20.180 / 54.1		Panel thickness		50,0 mm	Drawing ID
			Printed				20-09-14		internal number		Voltage	3x400 V / 50 Hz
			 PROKLIMA Member of  Group				Type					
							Model					
							KU 3-M-LU50S-S					

